



301 Fulling Mill Road | Middletown, PA 17057 | Phone: 717-944-5541 | Fax: 717-944-1430 | [www.alsglobal.com](http://www.alsglobal.com)

NELAP Certifications: NJ PA010 , NY 11759 , PA 22-293 DoD ELAP: PJLA 74618  
State Certifications: FL E871113 , WA C999 , MD 128 , VA 460157 , WV DW 9961-C , WV 343

Analytical Results Report For **Lyons Environmental Services, LLC**  
Project Ladacin Lehmann School  
Workorder 3227985  
Report ID 150776 on 2/21/2022

## Certificate of Analysis

Enclosed are the analytical results for samples received by the laboratory on Feb 16, 2022.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Sarah Leung (Project Coordinator) at (717) 944-5541.

Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at [www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads](http://www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads).

This laboratory report may not be reproduced, except in full, without the written approval of ALS Global.  
ALS Middletown: 301 Fulling Mill Road, Middletown, PA 17057 : 717-944-5541.

Recipient(s):

Donna Lyons - Lyons Environmental Services, LLC  
Carrie Lyons - Lyons Environmental Services, LLC.

*Sarah Leung*

**Sarah Leung**  
Project Coordinator

(ALS Digital Signature)

*This page is included as part of the Analytical Report and must be retained as a permanent record thereof.*



### Sample Summary

<u>Lab ID</u>	<u>Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>	<u>Collector</u>	<u>Collection Company</u>
3227985001	Field Blank	Drinking Water	02/16/2022 6:58 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985002	LCC1F	Drinking Water	02/16/2022 6:59 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985003	LCC2F	Drinking Water	02/16/2022 7:00 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985004	LCC3F	Drinking Water	02/16/2022 7:01 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985005	LCC4F	Drinking Water	02/16/2022 7:01 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985006	LCC5F	Drinking Water	02/16/2022 7:02 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985007	LCC6F	Drinking Water	02/16/2022 7:04 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985008	LCK2F	Drinking Water	02/16/2022 7:05 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985009	LCK1F	Drinking Water	02/16/2022 7:06 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985010	LCKICE1	Drinking Water	02/16/2022 7:07 AM	02/16/2022 8:45 PM	CBC	Collected By Client
3227985011	LCAWC1	Drinking Water	02/16/2022 7:09 AM	02/16/2022 8:45 PM	CBC	Collected By Client

---

## Reference

---

### Notes

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- Except as qualified, Clean Water Act sample analyses are consistent with methodology requirements in 40 CFR Part 136.
- Except as qualified, Safe Drinking Water Act sample analyses are consistent with methodology requirements in 40 CFR Part 141.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".
- For microbiological analyses, the "Prepared" value is the date/time into the incubator and the "Analyzed" value is the date/time out the incubator.
- An Analysis-Prep Method Cross Reference Table is included after Analytical Results & Qualifiers section in this report.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.

---

### Standard Acronyms/Flags

C	Please reference the Project Summary section of this Certificate of Analysis for case narrative comments.
J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

---



**Project Notations**

**Sample Notations**

**Lab ID**      **Sample ID**

**Result Notations**

**Notation #**  
0



Client Sample ID	<b>Field Blank</b>	Collected	<b>02/16/2022 6:58 AM</b>
Lab Sample ID	<b>3227985001</b>	Lab Receipt	<b>02/16/2022 8:45 PM</b>

**Metals Analytical  
 EPA 200.8**

**Prep**

<u>Method</u>	EPA ACIDT	<u>Container</u>	3227985001-A(Nitric Acid)
<u>Batch</u>	821142	<u>Aliquot</u>	100 mL
<u>Date</u>	02/20/2022 8:37 PM	<u>Tech.</u>	RMD

**Analysis**

<u>Method</u>	EPA 200.8	<u>Fraction</u>	
<u>Batch</u>	821143	<u>Dilution</u>	1
<u>Date</u>	02/20/2022 9:42 PM	<u>Analyst</u>	RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID **LCC1F**  
Lab Sample ID **3227985002**

Collected **02/16/2022 6:59 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985002-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:45 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID **LCC2F**  
Lab Sample ID **3227985003**

Collected **02/16/2022 7:00 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985003-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:46 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	0.0031 mg/L	0.0020	C



Client Sample ID	<b>LCC3F</b>	Collected	<b>02/16/2022 7:01 AM</b>
Lab Sample ID	<b>3227985004</b>	Lab Receipt	<b>02/16/2022 8:45 PM</b>

**Metals Analytical  
 EPA 200.8**

**Prep**

<u>Method</u>	EPA ACIDT	<u>Container</u>	3227985004-A(Nitric Acid)
<u>Batch</u>	821142	<u>Aliquot</u>	100 mL
<u>Date</u>	02/20/2022 8:37 PM	<u>Tech.</u>	RMD

**Analysis**

<u>Method</u>	EPA 200.8	<u>Fraction</u>	
<u>Batch</u>	821143	<u>Dilution</u>	1
<u>Date</u>	02/20/2022 9:47 PM	<u>Analyst</u>	RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND





Client Sample ID **LCC4F**  
Lab Sample ID **3227985005**

Collected **02/16/2022 7:01 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985005-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:48 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID **LCC5F**  
Lab Sample ID **3227985006**

Collected **02/16/2022 7:02 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985006-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:49 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID **LCC6F**  
Lab Sample ID **3227985007**

Collected **02/16/2022 7:04 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985007-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:50 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID	<b>LCK2F</b>	Collected	<b>02/16/2022 7:05 AM</b>
Lab Sample ID	<b>3227985008</b>	Lab Receipt	<b>02/16/2022 8:45 PM</b>

**Metals Analytical  
 EPA 200.8**

**Prep**

<u>Method</u>	EPA ACIDT	<u>Container</u>	3227985008-A(Nitric Acid)
<u>Batch</u>	821142	<u>Aliquot</u>	100 mL
<u>Date</u>	02/20/2022 8:37 PM	<u>Tech.</u>	RMD

**Analysis**

<u>Method</u>	EPA 200.8	<u>Fraction</u>	
<u>Batch</u>	821143	<u>Dilution</u>	1
<u>Date</u>	02/20/2022 9:51 PM	<u>Analyst</u>	RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID	<b>LCK1F</b>	Collected	<b>02/16/2022 7:06 AM</b>
Lab Sample ID	<b>3227985009</b>	Lab Receipt	<b>02/16/2022 8:45 PM</b>

**Metals Analytical  
 EPA 200.8**

**Prep**

<u>Method</u>	EPA ACIDT	<u>Container</u>	3227985009-A(Nitric Acid)
<u>Batch</u>	821142	<u>Aliquot</u>	100 mL
<u>Date</u>	02/20/2022 8:37 PM	<u>Tech.</u>	RMD

**Analysis**

<u>Method</u>	EPA 200.8	<u>Fraction</u>	
<u>Batch</u>	821143	<u>Dilution</u>	1
<u>Date</u>	02/20/2022 9:52 PM	<u>Analyst</u>	RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID **LCKICE1**  
Lab Sample ID **3227985010**

Collected **02/16/2022 7:07 AM**  
Lab Receipt **02/16/2022 8:45 PM**

**Metals Analytical**  
**EPA 200.8**

**Prep**

Method EPA ACIDT      Container 3227985010-A(Nitric Acid)  
Batch 821142      Aliquot 100 mL  
Date 02/20/2022 8:37 PM      Tech. RMD

**Analysis**

Method EPA 200.8      Fraction  
Batch 821143      Dilution 1  
Date 02/20/2022 9:54 PM      Analyst RMD

**RESULTS**

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



Client Sample ID	<b>LCAWC1</b>	Collected	<b>02/16/2022 7:09 AM</b>
Lab Sample ID	<b>3227985011</b>	Lab Receipt	<b>02/16/2022 8:45 PM</b>

**Metals Analytical  
 EPA 200.8**

**Prep**

<u>Method</u>	EPA ACIDT	<u>Container</u>	3227985011-A(Nitric Acid)
<u>Batch</u>	821142	<u>Aliquot</u>	100 mL
<u>Date</u>	02/20/2022 8:37 PM	<u>Tech.</u>	RMD

**Analysis**

<u>Method</u>	EPA 200.8	<u>Fraction</u>	
<u>Batch</u>	821143	<u>Dilution</u>	1
<u>Date</u>	02/20/2022 9:55 PM	<u>Analyst</u>	RMD

*RESULTS*

<u>Compound</u>	<u>CAS No</u>	<u>Result</u> <u>Units</u>	<u>RDL</u>	<u>Qualifiers</u>
Lead, Total	7439-92-1	ND mg/L	0.0020	C,ND



### Sample - Method Cross Reference Table

Lab ID	Sample ID	Analysis Method	Preparation Method	Leachate Method
3227985001	Field Blank	EPA 200.8	EPA ACIDT	
3227985002	LCC1F	EPA 200.8	EPA ACIDT	
3227985003	LCC2F	EPA 200.8	EPA ACIDT	
3227985004	LCC3F	EPA 200.8	EPA ACIDT	
3227985005	LCC4F	EPA 200.8	EPA ACIDT	
3227985006	LCC5F	EPA 200.8	EPA ACIDT	
3227985007	LCC6F	EPA 200.8	EPA ACIDT	
3227985008	LCK2F	EPA 200.8	EPA ACIDT	
3227985009	LCK1F	EPA 200.8	EPA ACIDT	
3227985010	LCKICE1	EPA 200.8	EPA ACIDT	
3227985011	LCAWC1	EPA 200.8	EPA ACIDT	





34 Dogwood Lane  
Middletown, PA 17057  
P. 717-944-5541  
F. 717-944-1430

# CHAIN OF CUSTODY/ REQUEST FOR ANALYSIS

ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT/  
SAMPLER. INSTRUCTIONS ON THE BACK.

Page 1 of 2

Courier:

Tracking #:

3227985

Logged By: CKW  
PM: SSL



Co. Name: Lyons Env, 732.566.0036  
Contact (Report to): Donnayons Phone:  
Address: 1105 Green Grove Rd. Bldg 2  
Neptune, NJ 07753

Bill to (if different than Report to):  
Lyons Env. PO#:

Project Name#: Ladacin Lehman School ALS Quote #:  
TAT:  Normal-Standard TAT is 10-12 business days. Date Required:  
 Rush-Subject to ALS approval and surcharges. Approved By:

Email?  Y  N  
Fax?  Y  N  
ALS: [als@lyonsenv.com](mailto:als@lyonsenv.com)

Sample Description/Location (as it will appear on the lab report)	COC Comments	Sample Date	Military Time	Matrix	Enter N
1 Field Blank		2/16/20	0658	D3	1
2 LCC1F			0659	D3	1
3 LCC2F			0700	D3	1
4 LCC3F			0701	D3	1
5 LCC4F			0701	D3	1
6 LCC5F			0702	D3	1
7 LCC6F			0704	D3	1
8 LCK2F			0705	D3	1

**Amy C.**  
Temp Taken By: wo  
WO Temp (°C): 510  
Therm ID: ACC  
Receipt Info Completed By: YN  
Cooler Custody Seal Intact: YN  
Sample Custody Seal Intact: YN  
Received on Ice: YN  
Cooler & Samples Intact: YN  
Correct Containers Provided: YN  
Sample Label/COC Agree: YN  
Adequate Sample Volumes: YN  
VOA Headspace Present: YN  
VOA Trip Blank: YN  
NJS 4 Days? YN  
Rad Screen (uCi): YN  
Courier/Tracking #: AM  
SDWA Compliance: Y  
PWSID: 0

Controlled by Sample Receiving  
Performed by: INITIAL HERE  
Cooler Temp: 6  
Therm ID: 510  
No. of Coolers:  
Notes:  
Correct containers? Y N  
Correct sample volume? Y N  
Correct preservation? Y N  
Headspace/Volatiles? Y N  
COC/Labels complete/accurate? Y N  
Received on ice? Y N  
Custody seals present? Y N  
Container in good condition? Y N  
Circle appropriate Y or N.

ALS FIELD SERVICES  
Pickup   
Labor   
Composite Sampling   
Rental Equipment   
Other:

Data Deliverables  
 Standard  
 CLP-like  
 NJ-Reduced  
 NJ-Full  
SDWA Farms?  yes  no  
State Samples Collected in?  MD  NJ  NY  PA  
If yes, format type:  Other  
Enter PWSID No.:

Project Comments:

Relinquished By / Company Name	Date	Time	Received By / Company Name	Date	Time
Donnayons	2/16/20	1900	AM	02/16/20	0950
AM			AM		
AM			AM		
AM			AM		
AM			AM		
AM			AM		
AM			AM		

Copies: WHITE - ORIGINAL CANARY - CUSTOMER COPY  
\* G=Grab; C=Composite  
\*\*Matrix: AL=Air; DW=Drinking Water; GW=Groundwater; OL=Oil; OL=Other Liquid; SL=Sludge; SO=Soil; WP=Wipe; WW=Wastewater  
\*\*\*Container Type: AG-Amber Glass; CG-Clear Glass; PL-Plastic. Container Size: 250ml, 500ml, 1L, 8oz., etc. Preservative: HCl, HNO3, NaOH, etc.  
Rev 01-2013



34 Dogwood Lane  
Middletown, PA 17057  
P. 717-944-5541  
F. 717-944-1430

**CHAIN OF CUSTODY/  
REQUEST FOR ANALYSIS**

ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT/  
SAMPLER. INSTRUCTIONS ON THE BACK.

Page 2 of 2  
Courier:  
Tracking #:

3227985 P9 2

Co. Name: **LYONS ENV.** 732.566.0037  
Contact (Report to): **Donnayons** Phone:  
Address: **1105 Green Grove Rd  
Naphtum, NJ 07753**  
Bill to (if different than Report to):  
**LYONS ENV. Radwin** PO#:  
Project Name/#: **Lehman School ALS Quote #:**

TAT:  Normal-Standard TAT is 10-12 business days. Date Required:  
 Rush-Subject to ALS approval and surcharges. Approved By:  
Email?  -Y No.  
Fax?  -Y No.

Sample Description/Location (as it will appear on the lab report)	COC Comments	Sample Date	Military Time	Enter Num
1 LCK1F		2/16	0706	1
2 LCKICE1		↓	0707	1
3 LCAWC1		↓	0709	1
4				
5				
6				
7				
8				

SAMPLED BY (Please Print): <b>Donnayons</b>		Project Comments:	
Relinquished By / Company Name	Date	Time	Received By / Company Name
<b>Donnayons</b>	2/16	1900	<b>AS</b>
<b>AS</b>			<b>AS</b>
<b>AS</b>			<b>AS</b>

ANALYSES/METHOD REQUESTED	
PL	PL
ASD	ASD
HNO3	HNO3

Receipt Information  
(Completed by Sample Receiving)  
Permit #:  
REF: HERE

Cooler Temp:  
Therm. ID:  
No. of Coolers:  
Notes:

Correct containers?	Correct sample volume?	Correct preservation?	Headspace/Voliles?	Circle appropriate Y or N.
Y	Y	Y	Y	Y
N	N	N	N	N
Y	Y	Y	Y	Y
N	N	N	N	N
Y	Y	Y	Y	Y
N	N	N	N	N

**Amc.**  
Temp Taken By: **Amc.**  
WO Temp (°C): **515**  
Therm ID: **515**  
Receipt Info Completed By: **AEL**  
Cooler Custody Seal Intact: **Y N**  
Sample Custody Seal Intact: **Y N**  
Received on Ice: **Y N NA**  
Cooler & Samples Intact: **Y N**  
Correct Containers Provided: **Y N**  
Sample Label/COC Agree: **Y N**  
Adequate Sample Volumes: **Y N**  
VOA Headspace Present: **Y N**  
Voa Trip Blank: **Y N**  
NLS-4 Days? **Y N**  
Rad Screen (uCi): **Y N**  
Courier/Tracking #: **Y N**  
SDWA Compliance: **Y N**  
PWSID: **Y N**

Standard	SDWA State Samples Collected in?	Other
<input checked="" type="checkbox"/> Standard	MD <input type="checkbox"/>	Other: <input type="checkbox"/>
<input type="checkbox"/> CLP-like	NJ <input checked="" type="checkbox"/>	
<input type="checkbox"/> NJ-Reduced	NY <input type="checkbox"/>	
<input type="checkbox"/> NJ-Full	PA <input type="checkbox"/>	

SDWA Compliance: **Y N**  
PWSID: **Y N**  
DOD Criteria Required?

**Appendix G**  
**Template for Lead Results - Lehmann Center**

Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Date Sampled	Time Sample	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit ug/L	Dilution Factor	Digested Y/N	Qualifier
Field Blank	N	3227985001	ALS	2/16/2022	6:58AM	EPA 200.8	2/20/2022	9:42PM	ND	15	1	Y	
LCAWC1	N	3227985011	ALS	2/16/2022	7:09AM	EPA 200.8	2/20/2022	9:55PM	ND	15	1	Y	
LCC1F	N	3227985002	ALS	2/16/2022	6:59AM	EPA 200.8	2/20/2022	9:45PM	ND	15	1	Y	
LCC2F	N	3227985003	ALS	2/16/2022	7:00AM	EPA 200.8	2/20/2022	9:44PM	3.1	15	1	Y	
LCC3F	N	3227985004	ALS	2/16/2022	7:01AM	EPA 200.8	2/20/2022	9:47PM	ND	15	1	Y	
LCC4F	N	3227985005	ALS	2/16/2022	7:01AM	EPA 200.8	2/20/2022	9:48PM	ND	15	1	Y	
LCC5F	N	3227985006	ALS	2/16/2022	7:02AM	EPA 200.8	2/20/2022	9:49PM	ND	15	1	Y	
LCC6F	N	3227985007	ALS	2/16/2022	7:04AM	EPA 200.8	2/20/2022	9:50PM	ND	15	1	Y	
LCK2F	N	3227985008	ALS	2/16/2022	7:05AM	EPA 200.8	2/20/2022	9:51PM	ND	15	1	Y	
LCKICE1	N	3227985010	ALS	2/16/2022	7:07AM	EPA 200.8	2/20/2022	9:54PM	ND	15	1	Y	
LCKIF	N	3227985009	ALS	2/16/2022	7:06AM	EPA 200.8	2/20/2022	9:52PM	ND	15	1	Y	